



# STORM Rating Report

TransactionID: 0  
Municipality: YARRA  
Rainfall Station: YARRA  
Address: 46 DUKE STREET  
  
RICHMOND  
VIC 3121  
Assessor: DX ARCHITECTS  
Development Type: Residential - Subdivision  
Allotment Site (m2): 183.00  
STORM Rating %: 133

Description	Impervious Area (m2)	Treatment Type	Treatment Area/Volume (m2 or L)	Occupants / Number Of Bedrooms	Treatment %	Tank Water Supply Reliability (%)
SITE COVERAGE A	77.00	Rainwater Tank	1,500.00	3	141.50	80.50
SITE COVERAGE B	78.00	Rainwater Tank	1,500.00	3	141.20	79.50
NON-PERMEABLE SURFACE	10.00	None	0.00	0	0.00	0.00